

ES DECLARATION ABOUT CONFORMITY WITH REGULATIONS.

Number: K4/006/2023/En



SEZ DK a.s.
M. R. Štefánika 1831/46
We, 026 19 Dolný Kubín
Slovenská republika
IČO: 36854174



declare on our own responsibility that the equipment labeled as follow according to its concept and construction as well as its functioning corresponds with the particular safety requirements by government regulation. When there are any changes on the equipment we do not agree with this declaration is not valid any more.

Product: Junction boxes with proven functionality in fire.
Type: PO 105 3P/4 (400402); PO 105 3P/4F (400404); PO 105 4P/4 (400403);
PO 105 5P/4 (400400); PO 105 3P/10 (400406); PO 105 3P/10F (400405);
PO 105 5P/10 (400401); PO 125 6P/4 (400410); PO 125 6P/10 (400411);
PO 155 9P/4 (400420); PO 155 3P/10 (400422); PO 155 6P/10 (400423);
PO 155 9P/10 (400421)
Parameters: Un/Ui 400V~; In 32A/4 mm²; In 57A/10 mm²; 3P-9P; IP55
Producer: SEZ DK a.s., M. R. Štefánika 1831/46, 026 19 Dolný Kubín
- Slovak republic, ID: 36854174
Function: Creating an electrical connection while maintaining functionality in fire conditions.
Authorized decrees of government: NV SR č. 148/2016; LVD 2014/35/EU;
Used harmonized norms, national norms and technical specifications: STN 92 0205: 2014/Z1:2019 - classification PS 30, PS 60, PS 90;
ČSN 73 0895: 2016 - classification P30-R, P60-R, P90-R;
DIN 4102-123: 1998-11 - classification E 30, E 60, E 90;
The product was judged according to: § 22 par. 1 letter a), h) act no. 56/2018 Coll. as amended
and it is consonant with ushered technical request of government decrees and laws.

Evaluation of congruity was made in cooperation with: FIRES s.r.o.
Osloboditeľov 282
059 35 Batizovce
Slovak republic

The Test report issued for the product: FIRES-JR-097-22-NURE day: 23.06.2022
FIRES-JR-098-22-NURE 23.06.2022
FIRES-JR-099-22-NURE 23.06.2022

The place: Dolný Kubín Name: Jozef ZVÁRA
Chairman of the Board of Directors

Date: 19.07.2023
SEZ DK a.s. ©

Stamp: M.R.Štefánika 1831/46
026 19 DOLNÝ KUBÍN

Function:
Signature: Ing. Rastislav BUTAŠ
Manažér technického oddelenia