



EVAKUATSIOONIVALGUSTI

DP-938L (ISETESTIV)



MÕÖDUD



EFEKTIIVSUS

Test Sequence	1	2	3	4	5	Maximum brightness / Minimum brightness
Luminance (cd/m ²)	73	49	43	50	28	
Test Sequence	6	7	8	9	10	270/28 9.6 ^ 10
Luminance (cd/m ²)	28	230	270	150	252	

TEHNILISED PARAMEETRID

Model No	Optical Parameters					Structural Parameters			
	Specification of Battery	Light Source	Emergency Time	Emergency Mode	Power	Material	Product Size (mm)	IP Rating	Certification
EX-DP938LED	3.6V 800mAh Ni-Cd	15 Pcs White LED	3 hour	Maintained	2W	Polycarbonate body+Double sided edge lit acrylic legend	340x45x214	IP 20	CE

Komplekti kuuluvad piktogrammide (3tk).

Lisainformatsiooni saamiseks palun pöörduda oma kliendihalduri poole.



IP 20

850 °C

